

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204957
Address: 2041 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, May 05, 2021

Corrective Action Required:

1	Misc	Builder requested garage portal wall framing and rear patio roof framing only: -Nail the garage PFH wall sheathing to sill plate with 8d @ 3" oc -Install straps -Tie down trusses to rear porch header
---	------	--

****Please do not cut out too much of the bottom garage PFH wall plates**

Comments: