


BOB D. CAMPBELL & CO.
Structural Engineers Since 1957
4338 Belleview Ave. 816.531.4144
Kansas City, MO 64111 www.bdc-engrs.com

PRINCIPALS

President
Michael J. Falbe, P.E.

Richard C. Crabtree, P.E.
Wayne E. Davis, P.E.
Jeffrey L. Wright, P.E.
Christopher W. Boos, P.E.
Clark A. Basinger, P.E.
Brandon M. Ford, P.E.
Christopher A. Beverlin, P.E.

Administrative Manager
Paul M. Spena

May 5, 2021

Mr. CW Keller
Slaggie Architects
4600 Madison
Kansas City, MO 64112

Re: Summit Orchards
Petland


Dear CW:

We have reviewed the roof framing for the rooftop mechanical equipment loading and find that it has the required strength and stiffness to support this loading. Unit anchorage curb design is the responsibility of the tenant finish team and has not been reviewed.

Please call if you have any questions or if we may be of further service.

Sincerely,

BOB D. CAMPBELL & CO.
Structural Engineers



Clark A. Basinger, P.E., Principal

cc: File / SLAGG1909

