

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202187
Address: 2025 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Joe Starlin	Partial	Thursday, May 06, 2021

Informational:
1 Misc 5-6-21 9:48am The water department has made the tap and Bair has ran the 1" line to the meter pit. They set the meter pit and ran the 2" copper water line to the footing per plan. They are now backfilling.

Comments: