

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203515

Address: 2608 SW WARD RD, LEES SUMMIT, MO 640822600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Steve Robbins	Passed	Tuesday, April 27, 2021

Informational:

1 Misc

The service water line has been installed, the sanitary sewer wye connection has been installed along with the pipe, the 6" fire line has been installed along with the hydrostatic test that passed. The water service line transitioned from a 2" copper to a 3" pvc pipe. We spoke with the water dept. and they said they did not have to take samples on this line.

Comments: