CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20203523

Address: 1520 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

Inspected On: Friday, May 07, 2021
Inspected By: Patrick Schonfeldt

Expiration Date: 5/28/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Patrick Schonfeldt Temporary C of O Friday, May 07,

Codes Residential 2021

Corrective Action Required:

1 Misc -RESOLVE OUTSTANDING INSPECTION FEE(S) BEFORE FINAL C OF O

-FINAL GRADE AND SOD

-SPLASH BLOCKS AT ALL DOWNSPOUT AND SUMP PUMP DISCHARGE LOCATIONS, MINIMUM 36" DISCHARGE FROM

FOUNDATION

OK FOR TCO - TCO EXPIRES 5/28/21