

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201567  
Address: 4030 SW BENZIGER DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Friday, May 07, 2021

Corrective Action Required:

1	Misc	-GFCI protection required at dishwasher receptacle -AFCI protection at all required circuits per code E3902.16, 210.12(A) - see kitchen receptacle circuits -Raise to grade MH H-4 at front of lot as shown on plot plan -Sidewalk at south side of driveway with ADA ramp-see approved plot plan
---	------	--

**Comments:**