

DEVELOPMENT SERVICES

Residential Plan Review

May 10, 2021

KC CUSTOM HOMES 209 SW LEWIS CT LEES SUMMIT, MO 64081 (816) 564-5149

Permit No: PRRES20212347

Plan Name: 146 NW AMBERSHAM DR.

Project Address: 146 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

Parcel Number: 224809

Location:

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - ENG. FLOOR SYSTEM - FINISHED AND UNFINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Verify Submittal (RES) Reviewed By: Development Center Incomplete

Waiting to Verify Submittal Reviewed By: Development Center Complete

Verify Contacts Reviewed By: Brandon Kalwei Complete

Verify Workitems and Add Sub Reviewed By: Brandon Kalwei Complete

Permits

Verify Development Agreements Reviewed By: Michael Weisenborn Pending

Plot Plan Review Reviewed By: Brandon Kalwei Rejected

Residential Plan Review Reviewed By: Brandon Kalwei Rejected

- 1. Two (2) copies of construction drawings. (Plans to be signed and sealed by an architect or engineer registered in the State of Missouri.) no address on plans
- 2. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

- 3. Footings, column pads, piers and grade beams dimensions. (IRC Section R403) not seeing any details for foundation plan
- 4. Footings, column pads, piers and grade beams reinforcement size and spacing.not seeing any details for foundation plan
- 5. Foundation wall thickness and height and reinforcement. (IRC Section R404) not seeing any details for foundation plan
- 6. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R501.3)
- 7. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

Internal Plan Review	Reviewed By: Brandon Kalwei	Rejected
Planning Review RES	Reviewed By: Brandon Kalwei	Pending
Waiting for Resubmittal	Reviewed By:	Recieved
Internal Plan Review	Reviewed By: Brandon Kalwei	Rejected
Residential Plan Review	Reviewed By: Brandon Kalwei	Rejected

- 1. Two (2) copies of construction drawings. (Plans to be signed and sealed by an architect or engineer registered in the State of Missouri.) no address on plans
- 2. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)
- 3. Footings, column pads, piers and grade beams dimensions. (IRC Section R403) not seeing any details for foundation plan
- 4. Footings, column pads, piers and grade beams reinforcement size and spacing.not seeing any details for foundation plan
- 5. Foundation wall thickness and height and reinforcement. (IRC Section R404) not seeing any details for foundation plan
- 6. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R501.3)
- 7. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

1. The legal description, including plat or phase number and lot number, and street address must be provided on the plot plan. If the driveway is coming off of Killarney then the address is 2203 NW Killarney Ln.

Planning Review RES	Reviewed By:	Pending
Waiting for Resubmittal	Reviewed By:	Recieved
Internal Plan Review	Reviewed By: Brandon Kalwei	Rejected
Residential Plan Review	Reviewed By: Brandon Kalwei	Rejected

- 1. Two (2) copies of construction drawings. (Plans to be signed and sealed by an architect or engineer registered in the State of Missouri.) no address on plans
- 2. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)
- 3. Footings, column pads, piers and grade beams dimensions. (IRC Section R403) not seeing any details for foundation plan
- 4. Footings, column pads, piers and grade beams reinforcement size and spacing.not seeing any details for foundation plan
- 5. Foundation wall thickness and height and reinforcement. (IRC Section R404) not seeing any details for foundation plan
- 6. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R501.3)
- 7. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

Plot Plan Review Reviewed By: Brandon Kalwei Rejected

1. The legal description, including plat or phase number and lot number, and street address must be provided on the plot plan. If the driveway is coming off of Killarney then the address is 2203 NW Killarney Ln.

Planning Review RES Reviewed By: Pending

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:					
Residential, Decks		254			
Residential, Finished basements		1441			
Residential, garage		943			
Residential, Living Area		1948			
Residential, Un-Finished basements		314	314		
Roofing Material		Number of Bathrooms	3 full and 2, 1/2		
Number of Bedrooms	3	Number of Stories	1		
Number of Living Units	1	Total Living Area	3389		
Sewer Connection Fee	19				