

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20202118
Address: 4405 SW ALABASTER CIR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, May 11, 2021
Inspected By: Patrick Schonfeldt
Expiration Date: 6/1/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|------------------|--------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Temporary C of O | Tuesday, May 11, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Final grade and sod -(2) through bolts at each post/beam connection at deck -R507.5.1 (2) 1/2" diameter through bolts required -Splash blocks at all downspout and sump pump discharge locations, minimum 36" discharge from foundation |
|---|------|--|

****OK FOR TCO - TCO EXPIRES 6/1/21****