

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201014
Address: 2751 NE DOUGLAS ST, Unit:V, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Tuesday, May 11, 2021

Corrective Action Required:

1	Misc	-The mechanical equipment is now on 2nd floor. The 2-hr fire barrier enclosure around the furnace is not framed at this moment. The wall&ceiling inside of the closet below the furnace is protected with 2 layers of 5/8" rock -The office/hangar 1 hour wall is completed
---	------	--

Comments: