

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210481

Address: 2550 SW 3RD ST, LEES SUMMIT, MO 64081141 NW MORTON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary - Material Verification	Ronald Paynter	Passed	Tuesday, May 11, 2021

Informational:

1 Misc

Manholes were manufactured by Barbour Concrete with ML-13-NCR steps. Sanitary pipes for the main line are 8 inch SDR 26 were manufactured by Sanderson Pipe. Sanitary pipes for the service laterals are 4 inch SDR 26 manufactured by Sanderson Pipe. Manhole casting are 1502A manufactured by EJ USA and have the correct stamping on the lids. RP 5-3-21

Comments: