

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203598
Address: 2349 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Wednesday, May 12, 2021

Informational:

1	Misc	No deck inspection at all trades
---	------	----------------------------------

Corrective Action Required:

2	Misc	Not ready for inspection. no building address, no water to fixtures, incomplete guardrails, open outlet boxes and so on
---	------	---

Comments: