



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20210599	Date:	May 12, 2021
Project Title:	SHAKE SHACK #1348	Applicant:	
Location:			
2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081		Eclipse Integrations LLC	
Type of Work:		21808 S Wheatfield Rd	
Occupancy Group:	A-2	Peculiar, MO 64078	
Description:	NEW BUILDING FOR A	Primary: (816) 716-1733	
RESTAURANT WITH DRIVE-THRU AND PATIO SEATING			

Construction Type: Type IIB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 for testing.

Locate outside horn/strobe by FDC

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.