

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211100
Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Wednesday, May 12, 2021

Corrective Action Required:

1	Misc	-cover plate on receptacle at mech/laundry for data -cover plate at data box at laundry wall -firecaulk at plumbing wall penetrations in laundry rated wall -GFCI at sink receptacle - emergency exterior illumination not lighting on backup as required
---	------	---

OK TO STOCK AND TRAIN

Comments: