

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211979
Address: 516 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|------------|----------|-------------------------|
| Erosion Control | Robb Popp | Failed | Wednesday, May 12, 2021 |

Corrective Action Required:

| | | |
|---|----------------------------|---|
| 1 | DCM3 ESC REQUIRED 2 DAY | 5-12-21 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -EROSION CONTROL IS REQUIRED AS SOON AS LAND DISTURBANCE BEGINS AND MUST BE MAINTAINED UNTIL FINAL COMPLETION -PROVIDE ADEQUATE EROSION CONTROL AT PERIMETER OF LOT, AROUND STOCKPILES, AND GRAVEL DRIVE WITH 3/4' GRAVEL IN MIN. 6" LIFT -REPLACE OVERGROWN GUTTER BUDDY AT STORM INLET |
|---|----------------------------|---|

Comments: