

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210149
Address: 2104 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Wednesday, May 12, 2021

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	- MAINTAIN SILT FENCE - DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	---------------------------------------	---

Corrective Action Required:

2	DCM6 ESC INSP DENIED STREET CLEAN UP	STREET CLEAN UP REQUIRED MAINTAIN SILT FENCE MAINTAIN GRAVEL FILTER
---	--	---

Comments: