

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210484
Address: 3552 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Friday, May 14, 2021

Corrective Action Required:

1	Misc	-GFCI protection at wall receptacle above sink at laundry room -Hammer arrestors at laundry -Install mirror at sink in bathroom -remove previous tenant circuit breaker locations marked in service panel -see inspection report for fire corrections
---	------	---

****OK TO STOCK AND TRAIN****

Comments: