

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202362
Address: 2357 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, May 14, 2021

Corrective Action Required:

1	Misc	**RESTORE EROSION CONTROL ALONG THE SIDE AND REAR OF LOT -Nail CSPF wall siding per code -Fb wall at refrigerator from roof -Brace lvl beam at end (above 16" lvl) and at 1/3 point per plan -Fb wall space at basement bathroom tub -Protect plumbing at top plate in laundry -Bond gas piping **OK TO INSULATE
---	------	---

Comments: