

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	John Morris	Partial	Friday, May 14, 2021

Corrective Action Required:

1	Misc	413 -AFCI/GFCI at dishwasher circuit 414 -install another tip at range -Self closing and latching door at corridor 415 -faulty exterior GFCI receptacle 418 -loose guardrail at balcony 1-4A panel room, open panel for label. Correct fire damper control in wall over door. Inspected and OK -404 ,407,409,410,420,419,422,428,429, 401, 402, 403, 405, 406, 408, 411, 412, 416, 417, 421, 423, 424, 425, 426, 427
---	------	---

Corrective Action Required:

2	FOURTH FLOOR	Pre final -units approved:
---	--------------	----------------------------

444-459,431- 443 ,460-465.
, 425A,421A,424B,
Corridor 412
5/13/21
Following
"B" side
Ok-429,428,404 ,407,422,409,420,419,410,

Corrective Action Required:

3 THIRD FLOOR 3/29/21
331-367;
324B

Corrective Action Required:

4 SECOND FLOOR 4/8/21 4/9/21
; 255 -263 ;265-267;221A,230-253;
225A ok
220A ok

Corrective Action Required:

5 FIRST FLOOR 4/12/21
117--138;

120A ok

Corrective Action Required:

6 THE FOLLOWING Pre Final areas approved are the following;
AREAS ARE see sepertate floor levels.
APPROVED *:

Comments: