

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201997
Address: 4401 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, May 17, 2021

Corrective Action Required:

1	Misc	-No pier inspection performed at covered deck- Submit engineer letter -Complete sidewalk at front of lot -Add splash block or extension to sump pump discharge, min 36" discharge from foundation (2) bolts at each post/beam connection at deck per code, see R507.5.1(2) , (2) 1/2" diameter through bolts required at each post/beam connection
---	------	---

Comments: