

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200878
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Monday, May 17, 2021

Corrective Action Required:

1	Misc	Ineffective erosion control methods in southwest corner of property. Straw waddles have not been able keep silt and debris on the property, please install silt fence in this area to keep mud/debris off city sidewalk and street until sod is installed. Immediate cleanup of sidewalk and street is required.
---	------	--

Comments: