

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200874
Address: 1805 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|----------------------|
| Occupancy Inspection - Codes Residential | John Morris | Failed | Monday, May 17, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Irrigation permit required -Remove debris from storm water inlet -Address failed plot plan inspection -Provide tamper resistant schrader valve caps at exterior HVAC equipment -Provide handrail at stairs to garage -Identify circuit 19 in main panel |
|---|------|---|

Comments: