

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

---

Permit #:PRPWRW20212362, Public Works Right of Way Permit  
Address: 537 SW MARKET ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit Inspection</b>		Partial	Monday, May 17, 2021

Corrective Action Required

1 Misc

Site Visit - Jeremiah called in an inspection, when I arrived the approach was full of water due to the rain and needs to have gravel put down in the approach and be compacted properly. I called Jeremiah and Ed the owner to let them know gravel is required. Ed said they would take care of it and are waiting till it dries up. The forms were set to achieve compliance. They will call in another inspection once the gravel is in place.

**Comments:**