



May 14, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of ridge beam cut 9" short for Lot # 88 Woodside Ridge – 310 NW Ambershame Dr. Lee's Summit, MO 64081 – Permit # PRRES20204988

This letter addresses the field issue of ridge beam cut 9" short for Lot # 88 Woodside Ridge. Revision to second floor framing shall be as follows:

- Trim 1.5" off rafters on each side for rafter bay adjacent to bay with no ridge beam.
- Sister (2) 2x6 #2 Douglas Fir Larch approximately 2' long on each side of ridge beam. Fasten with 2.5" long 8D nails in a "W" pattern, 4 nails per linear foot.
- Attach rafters to sistered #2 2x6 per IRC table R602.3(1).

Sincerely,

Bradley Huxol, PE

