

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202107
Address: 4408 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, May 17, 2021

Corrective Action Required:

1	Misc	-Install spindles at basement stairs -Anti siphon device required at spigot on main water line in basement, ensure set screw head is clipped off anti siphon after installation -(2) 1/2" through bolts required at each post/beam connection per code at deck, R507.5.1(2)
---	------	---

Comments: