

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200162
Address: 1709 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Tuesday, May 18, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Complete sod installation -Complete HVAC installation, exterior equipment -provide proper bearing of deck joists at ledger connections -Permanent handrail required at front stoop
---	--------------------------	--

TCO EXTENSION VALID THROUGH 03/19/21 DUE TO WEATHER CONDITIONS

Corrective Action Required:

2	Miscellaneous Correction	The temporary certificate of occupancy has expired at this address. If remaining correction items are complete please schedule an occupancy inspection. If remaining correction items are not complete a permit extension request must be submitted in writing with the expected date of completion.
---	--------------------------	--

Comments: