

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204685
Address: 2911 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, May 18, 2021

Corrective Action Required:

1	Misc	-ADD BOCCA PROTECTION PLATE TO BOTTOM PLATE DWV BATH -FIREBLOCK BETWEEN TOP PLATE AND FOUNDATION WALL AT SERVICE PANEL
---	------	---

Comments: