

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Tuesday, May 18, 2021

Informational:

1 THIRD FLOOR

-AREAS APPROVED-

BUILDING C

RC CHANNEL ROOMS 3019-3031

RC CHANNEL MECHANICAL ROOM CEILINGS 3019-3031, CORRIDOR CEILING

RC CHANNEL CORRIDOR WALLS AND CEILING TO SHAFT WALL

SHOWER BUILD OUT CEILINGS 3031,3030,3029,3028,3027,3026,3025,3024,3023,
3022, 3020, 3006, 3007,3008, 3011, 3012,3018,

ROCK BEHIND SHOWERS 3019-3031

FIRST LAYER ROOMS IN BATHROOMS AND LAUNDRY ROOMS CEILINGS:

-3018-3031

MECHANICAL ROOM CEILINGS:

-3018-3031

ROOMS OK FOR RC: 3041, 3040, 3045, 3002,

BUILDING B

RC CHANNEL MECHANICAL ROOM CEILINGS 3003-3016

RC CHANNEL ROOMS 3003-3016

RC CHANNEL CORRIDOR WALLS AND CEILINGS TO SHAFT WALL

FIRST LAYER ROOMS BATHROOM AND LAUNDRY ROOM CEILINGS:

-3001-3016

		MECHANICAL ROOMS: -3001-3016
		BUILDING A RC CHANNEL CORRIDOR WALLS AND CEILING TO SHAFT WALL
Informational:		
2	SECOND FLOOR	-AREAS APPROVED-
		BUILDING C: MECHANICAL ROOM CEILINGS 2019, 2020, 2022, 2024-2031 ROCK BEHIND SHOWERS AT SHEAR WALLS 2019-2031 RC CHANNEL ROOMS 2019-2031 RC CHANNEL CORRIDOR WALLS AND CEILING TO SHAFT WALL
		BUILDING B: ROCK BEHIND SHOWERS AT SHEAR WALLS 2005,2007,2008,2011-2015 RC ROOMS 2003-2016 RC CHANNEL CORRIDOR WALLS AND CEILNG TO SHAFT WALL
		BUILDING A: RC CHANNEL ROOMS: 2039-2042, 2044 RC CHANNEL CORRIDOR WALLS AND CEILNIG TO SHAFT WALL
Informational:		
3	FIRST FLOOR	-AREAS APPROVED-
		BUILDING C CORRIDOR WALLS AND CELINGS OK FOR SOFFITS TO SHAFT WALL PRE ROCK BEHIND SHOWERS ROOMS: -1015-117, 1020-1023, 1025-1030,
		BUILDING B CORRIDOR WALLS AND CELINGS OK FOR SOFFITS TO SHAFT WALL PRE ROCK BEHIND SHOWERS ROOMS: -1001-1004, 1007, 1009, 1010, 1013, 1014
		BUILDING A CORRIDOR WALLS AND CELINGS OK FOR SOFFITS TO SHAFT WALL PRE ROCK BEHIND SHOWERS ROOMS: -1016
		OK TO INSTALL RC FOR SOFFITS IN CORRIDOR THROUGHOUT MCAL BUILDING: RM 165 NORTH WALL LAYER OVER SHAFT WALL
Corrective Action Required:		
4	Miscellaneous Correction	5-17-21 -COMPLETE DRYWALL AND RC AT SHAFT WALL IN END UNITS 2018,2020,2001,2002

Comments:

