

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203927  
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Morris	Partial	Thursday, April 22, 2021

Informational:	
1 Misc	gas piping and pressure test approved in market grille area
Corrective Action Required:	
2 Misc	Welded gas piping on roof top pressure test approved. Secure piping to blocks and paint piping with corrosion resistant material

**Comments:**