

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203927
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Morris	Partial	Wednesday, May 19, 2021

Informational:

1 Misc gas piping and pressure test approved in market grille area

Corrective Action Required:

2 Misc Welded gas piping on roof top pressure test approved. Secure piping to blocks and paint piping with corrosion resistant material

Comments: