

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201877

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	John Jackson	Failed	Wednesday, May 19, 2021

Informational:

1 Misc

Contractor has maintained construction entrance we will continue to monitor site to ensure sediment doesn't leave the site.

Informational:

2 Misc

2/3/21 Wednesday

Erosion controlled failed - sediment around the site and gutter buddies have not been installed.

5/16/21 Wednesday

Erosion controlled failed - along NE Jamestown gutter buddies need to be clean out and heavy silt in the street.

Comments: