

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204497
Address: 111 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|-------------------------|
| Occupancy Inspection - Codes Commercial | Robb Popp | Failed | Wednesday, May 19, 2021 |

Corrective Action Required:

| | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | -Pay all fees before occupancy -Provide health department approval -Install all equipment -Provide back flow device for beverage dispensers -Correct gaps at outlet in kitchen and switch in bathroom -Provide RTU screen as per planning division |
|---|--------------------------|---|

Comments: