

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Partial	Wednesday, May 19, 2021

Corrective Action Required:

1 Misc

FOLLOWING UNIT REQUIRE CORRECTIONS

314 ADA PROVIDE INSULATION SINK & VANITIES, SEAL EXTERIOR PENETRATIONS

201 UNIT # CORRIDOR

204 COVER PLATE LAUNDRY, COMPLETE FAUCETS & DRAIN MASTER BATH

207 GFCI DISHWASHER

222 GFCI ISLAND HOT NEUTRAL REVERESED

Corrective Action Required:

2 FOURTH FLOOR

Pre final -units approved:
444-459,431- 443 ,460-465.
, 425A,421A,424B,
Corridor 412
5/13/21
Following
"B" side
Inspected 401-429;

Corrective Action Required:

3 THIRD FLOOR

3RD FLOOR UNITS APPROVED

3/29/21
331-367;
324B

5/17/21
301-313,315-329, APPROVED

Corrective Action Required:

4 SECOND FLOOR 2ND FLOOR UNITS APPROVED
; 255 -263 ;265-267;221A,230-253;
225A ok
220A ok
202-203 205-206 223-229

Corrective Action Required:

5 FIRST FLOOR 4/12/21
117--138;

Corrective Action Required:

6 THE FOLLOWING Pre Final areas approved are the following;
AREAS ARE see sepertate floor levels.
APPROVED *:

Comments: