

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191603
Address: 2421 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Thursday, May 20, 2021

Corrective Action Required:

1	Misc	- Obtain irrigation system permit and submit backflow certification for approval-
---	------	---

Corrective Action Required:

2	Misc	The temporary certificate of occupancy has expired at this address. If remaining correction items are complete please schedule an occupancy inspection. If remaining correction items are not complete a permit extension request must be submitted in writing with the expected date of completion.
---	------	--

Comments: