

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203513
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Michael Harkins	Partial	Thursday, May 20, 2021

Informational:
1 Misc

- UNDERGROUND CONDUIT FOR PRIMARY SOUTH END OF TENNIS COURTS -
- 6" & 8" CONDUIT 34' TO SOUTH @ SE END OF TENNIS COURT -
- 100' TO SOUTH @ SE END OF TENNIS COURT -
- (2) DRIVEN GROUND RODS OUTSIDE ELECTRICAL ROOM DOOR RESTROOMS BLDG -

Comments: