

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Partial	Thursday, May 20, 2021

Corrective Action Required:

1	Misc	FOLLOWING UNIT REQUIRE CORRECTIONS
		314 ADA PROVIDE INSULATION SINK & VANITIES, SEAL EXTERIOR PENETRATIONS
		201 UNIT # CORRIDOR
		204 COVER PLATE LAUNDRY, COMPLETE FAUCETS & DRAIN MASTER BATH
		219 COPING AT DECK RAIL
		220 COPING AT DECK RAIL
		221 GFCI DISHWASHER, COVER PLATE DINING ROOM
		206B TRASH ROOM MISSING COVER PLATE/DEVICE
		204A FIRE CAULK CEILING
		210A FIRE CAULK CEILING

Corrective Action Required:

2	FOURTH FLOOR	Pre final -units approved: 444-459,431- 443 ,460-465. , 425A,421A,424B, Corridor 412 5/13/21 Following
---	--------------	---

		"B" side Inspected 401-429;
Corrective Action Required:		
3	THIRD FLOOR	3RD FLOOR UNITS APPROVED 3/29/21 331-367; 324B
		5/17/21 301-313,315-329, MECH,TRASH,ELEC APPROVED
Corrective Action Required:		
4	SECOND FLOOR	2ND FLOOR UNITS APPROVED ; 255 -263 ;265-267;221A,230-253; 225A ok 220A ok AREA B 202-203 205-218 222-229
Corrective Action Required:		
5	FIRST FLOOR	4/12/21 117--138;
Corrective Action Required:		
6	THE FOLLOWING AREAS ARE APPROVED	Pre Final areas approved are the following; see sepertate floor levels. *:

Comments: