David P. Ainsworth, P.E. 1200 NW Hearnes Ave, Blue Springs, MO 64015 Cell Phone: 816-682-2093 Email: dainsworth@chelepis.com

May 20, 2021

Dave Richards, Jr.
Dave Richards Homebuilding, Inc.
P.O. Box 1325
Blue Springs, MO 64013

Re: 1100 NE Goshen Ct,
Monticello Lot 84
Lee's Summit, MO
Fisher Plan
Deck Support Piers and Anchorage

Dear Mr. Richards:

On May 20, 2021, I inspected the deck support piers and anchorage at the above referenced address. The support piers as installed are adequate to support the imposed loads.

The model number of the deck support post anchorage is ABA66R2 and $\frac{1}{2}$ " x 5-1/2" wedge anchors were used. The installation was done in accordance with the manufacturer's recommendations.

In summary, the deck support piers and anchorage as installed is adequate for the imposed loads.

Cordially,

David P. Ainsworth, P.E.

5-20-2)