

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20204843  
Address: 129 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, May 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	Install back ordered windows & doors PFH portal frame garage fasten top plate to header with two rows of 16D sinkers @ 3" OC per plan Nail studs at intersecting wall corners at braced wall panels Provide 6 x 6 full height continuous post covered deck per plan Secure bath exhaust with metallic tape bath # 2 Provide SCH 40 column under stairs near service panel per plan Provide CS-PF ext bracing at back ordered windows south rear wall basement per plan Provide WSP Bracing bed 2 per plan
---	--------------------------	--

Comments: