

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210149
Address: 2104 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, May 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	Seal upward penetration (low volt) near range (Seal at top plate to seal floor joist cavity)
		Fire block behind header at refrigerator range side
		Seal dead space entry closet at joist

Comments: