

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204325
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	John DiMauro	Failed	Thursday, May 20, 2021

Corrective Action Required:

1	Misc	Everything is set up fine, rock is good and forms are good, Subgrade it too wet. Please call in another inspection when subgrade is dried out.
---	------	--

Comments: