

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204325
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Troy Thompson	Passed	Monday, May 24, 2021

Informational:
1 Misc The forms look good and is ready to pour except for the fact that it is raining and the subgrade is too wet to pour concrete. I am failiing because of rain.

Comments: