

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200776
Address: 114 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Joe Starlin	Passed	Monday, May 24, 2021

Informational:
1 Misc 5-24-21 2:04pm We have started the hydrostatic test for the fire hydrant. The gauge was at 200 at 1:25pm. I will check again at 3:25pm. 3:25pm The line has held at 200 psi. It has passed.

Comments: