CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20202635

Address: 4404 SW NAUTILUS PL, LEES SUMMIT, MO 64082

Inspected On: Tuesday, May 25, 2021
Inspected By: Patrick Schonfeldt

Expiration Date: 6/22/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Patrick Schonfeldt Temporary C of O Tuesday, May 25,

Codes Residential 2021

Corrective Action Required:

1 Miscellaneous -Final grade per approved plot plan

Correction -Sod

-Splash blocks at all downspout and sump pump discharge

locations, min 36" discharge from foundation

OK FOR TCO - TCO EXPIRES 6/22/21