

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20200776  
Address: 114 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Fire Hydrant</b>	Joe Starlin	Passed	Tuesday, May 25, 2021

Informational:  
1 Misc 5-25-21 8:43am Breit has flushed the fire line for 5 minutes. The line is approximately 80' long.

**Comments:**