

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202122  
Address: 137 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                 | Inspector:  | Outcome: | Date:                 |
|-----------------------------|-------------|----------|-----------------------|
| <b>Plot Plan Inspection</b> | John Morris | Failed   | Tuesday, May 25, 2021 |

Corrective Action Required:

|   |      |                                                                                                  |
|---|------|--------------------------------------------------------------------------------------------------|
| 1 | Misc | -Remove silt from swale<br>-locate and expose fire hydrant valve lid, ensure accessible at grade |
|---|------|--------------------------------------------------------------------------------------------------|

**Comments:**