

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201545
Address: 1021 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Failed	Tuesday, May 25, 2021

Corrective Action Required:

1	Misc	-Maintenance of erosion control Methods is Required until sod is in place -final grade & sod -Irrigation permit required -No building address. Minimum 4 inch height, half-inch stroke, on contrasting background and in illuminated area -Paint exterior gas piping -Complete electrical installation of master bedroom, ceiling fan installation -Secure water sprinkler piping in basement unfinished area -Self closing & self latching garage/dwelling separation door -Provide properly sized OCPD, condensing unit
---	------	---

Comments: