

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203284  
Address: 4417 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Wednesday, May 26, 2021

Corrective Action Required:

1	Misc	-Obtain lawn irrigation system permit -Upload engineer letter to permit concerning drilled footing piers as requested at footing inspection 11/2/20 -Final grade -Sod -Guardrail required at front porch, more than 30" from grade -Splash blocks at all downspout and sump pump discharge locations, min 36" discharge from foundation -Anchor steel column to floor at suspended slab basement
---	------	--

Comments: