

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204535  
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, May 26, 2021

Corrective Action Required:

1	Miscellaneous Correction	PFH: -COMPLETE NAILING PATTERN AT HEADER -NAIL INTERIOR TENSION STRAPS -MISSING NUTS/ WASHER AT ANCHOR BOLTS -PROVIDE 2 ROWS 16d SINKERS 3" OC AT HEADER TO TOP PLATE PER DETAIL  DECK: -UNCOVER BEAMS/ COLUMNS AND ALL CONNECTIONS FOR INSPECTION
---	--------------------------	---

Comments: