

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204450
Address: 2013 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, May 26, 2021

Corrective Action Required:

1	Misc	Tyvek tape nail penetrations in tyvek wrap STILL NAIL PENETRATIONS FRONT BEDROOM, DECK & BRACED WALL PANELS Provide 1 1/2 bearing deck beam OR LEDGER LOCK SIDES TO HOUSE PER CODE AND USE SIMPSON CONCEALED FLANG DOUBLE JOIST HANGER HUC212-2 OR EQUIVALENT : Ok to insulate :
---	------	---

Comments: