

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20210599	Date:	May 27, 2021
Project Title:	SHAKE SHACK #1348	Applicant:	
Location:			
2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081		ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	A-2	GRANDVIEW, MO 64030	
Description:	NEW BUILDING FOR A		
RESTAURANT WITH DRIVE-THRU AND PATIO SEATING		Primary: (816) 737-9991	

Construction Type: Type IIB (Unprotected)  
Map Page:

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic and water flow test.

2. (Informational Purposes)

Relocate FDC to the North end of the building.

FDC to be 100' from hydrant.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**