

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210350
Address: 1425 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, May 27, 2021

Corrective Action Required:

1	Misc	**APPROVED TRUSS PLANS/DRAWINGS REQ ON SITE IF BEING INSPECTED WITH GARAGE PORTAL**
---	------	--

5/27/21 GARAGE PORTAL INSPECTION

-HEADER TO JACK STUD STRAPS REQUIRED, SEE TABLE R602.10.6.4

-FASTEN TOP PLATE TO HEADER WITH TWO ROWS 16D NAILS AT 3" O.C.

Comments: